

APPLIANCE TESTING CERTIFICATE

Certificate No.: 37

Instrument Serial No.:

1000-755/101035672

CLIENT AND LOCATION DETAILS

KBS Inflatable Kingdom
Unit 2 Crowborough Business Park
Park Road
Crowborough
TN6 2GZ

Blackhawk Security Ltd
Unit 6A Crowborough Business Park
Park Road
Crowborough
TN6 2GZ

TEST RESULTS

Asset ID	Description	Test Date	Class	Volts	Visual	Cont	Ins.	Oper.	Leak.	Extn.	Flash	RCD I	RCD 5I	Status
KBS001040	2M EXTENSION LEAD	23/04/2026	1	230	Pass	0.05	>99.90			Pass				Pass
KBS001044	2M EXTENSION LEAD	23/04/2026	1	230	Pass	0.07	>99.90			Pass				Pass
KBS001047	IEC BLOCK ADAPTOR	23/04/2026	1	230	Pass	0.06	>99.90			Pass				Pass
KBS001048	IEC BLOCK ADAPTOR	23/04/2026	1	230	Pass	0.06	>99.90			Pass				Pass
KBS001064	AIR BLOWER	23/04/2026	1	230	Pass	0.07	>99.90		<0.10					Pass
KBS001067	AIR BLOWER	23/04/2026	1	230	Pass	0.09	>99.90		<0.10					Pass
KBS001073	AIR BLOWER	23/04/2026	1	230	Pass	0.09	>99.90		<0.10					Pass
KBS001074	AIR BLOWER	23/04/2026	1	230	Pass	0.10	>99.90		<0.10					Pass
KBS001078	AIR BLOWER	23/04/2026	1	230	Pass	0.07	>99.90		<0.10					Pass
KBS001079	AIR BLOWER	23/04/2026	1	230	Pass	0.10	>99.90		<0.10					Pass
KBS001083	AIR BLOWER	23/04/2026	1	230	Pass	0.07	>99.90		<0.10					Pass
KBS001084	AIR BLOWER	23/04/2026	1	230	Pass	0.11	>99.90		<0.10					Pass
KBS001085	AIR BLOWER	23/04/2026	1	230	Pass	0.12	>99.90		<0.10					Pass
KBS001087	AIR BLOWER	23/04/2026	1	230	Pass	0.07	>99.90		<0.10					Pass
KBS001088	AIR BLOWER	23/04/2026	1	230	Pass	0.12	>99.90		<0.10					Pass
KBS001089	AIR BLOWER	23/04/2026	1	230	Pass	0.07	>99.90		<0.10					Pass
KBS001090	AIR BLOWER	23/04/2026	1	230	Pass	0.14	>99.90		<0.10					Pass
KBS001091	AIR BLOWER	23/04/2026	1	230	Pass	0.07	>99.90		<0.10					Pass
KBS001092	AIR BLOWER	23/04/2026	1	230	Pass	0.10	>99.90		<0.10					Pass
KBS001093	AIR BLOWER	23/04/2026	1	230	Pass	0.12	>99.90		<0.10					Pass
KBS001094	AIR BLOWER	23/04/2026	1	230	Pass	0.12	>99.90		<0.10					Pass
KBS001094	AIR BLOWER	23/04/2026	1	230	Pass	0.11	>99.90		<0.10					Pass
KBS001096	AIR BLOWER	23/04/2026	1	230	Pass	0.10	>99.90		<0.10					Pass
KBS001097	AIR BLOWER	23/04/2026	1	230	Pass	0.08	>99.90		<0.10					Pass
KBS001098	AIR BLOWER	23/04/2026	1	230	Pass	0.12	>99.90		<0.10					Pass
KBS001113	EXTENSION LEAD	23/04/2026	1	230	Pass	0.08	>99.90			Pass				Pass
KBS001115	EXTENSION LEAD	23/04/2026	1	230	Pass	0.08	>99.90			Pass				Pass
KBS001116	2M EXTENSION LEAD	23/04/2026	1	230	Pass	0.06	>99.90			Pass				Pass
KBS001145	2M EXTENSION LEAD	23/04/2026	1	230	Pass	0.05	>99.90			Pass				Pass
KBS001152	2M EXTENSION LEAD	23/04/2026	1	230	Pass	0.06	>99.90			Pass				Pass
KBS001162	AIR BLOWER	23/04/2026	1	230	Pass	0.13	>99.90		<0.10					Pass
KBS001163	AIR BLOWER	23/04/2026	1	230	Pass	0.09	>99.90		<0.10					Pass
KBS001167	AIR BLOWER 2	23/04/2026	1	230	Pass	0.12	>99.90		<0.10					Pass
KBS001170	AIR BLOWER	23/04/2026	1	230	Pass	0.08	>99.90		<0.10					Pass
KBS001173	AIR BLOWER	23/04/2026	1	230	Pass	0.10	>99.90		<0.10					Pass
KBS001174	AIR BLOWER	23/04/2026	1	230	Pass	0.08	>99.90		<0.10					Pass
KBS001176	AIR BLOWER	23/04/2026	1	230	Pass	0.09	>99.90		<0.10					Pass
KBS001218	2M EXTENSION LEAD	23/04/2026	1	230	Pass	0.06	>99.90			Pass				Pass

CONTRACTOR DETAILS

Blackhawk Security Ltd
Unit 5 Crowborough Business Park
Park Road
Crowborough
East Sussex TN6 2GZ

Tester Name Chris Hawkes
Qualifications City & Guilds 600/3528/6 - 600/3597/3
Position Director

Signature



APPLIANCE TESTING CERTIFICATE

Certificate No.: 37

Instrument Serial No.:

1000-755/101035672

CLIENT AND LOCATION DETAILS

KBS Inflatable Kingdom
Unit 2 Crowborough Business Park
Park Road
Crowborough
TN6 2GZ

Blackhawk Security Ltd
Unit 6A Crowborough Business Park
Park Road
Crowborough
TN6 2GZ

TEST RESULTS

Asset ID	Description	Test Date	Class	Volts	Visual	Cont	Ins.	Oper.	Leak.	Extn.	Flash	RCD I	RCD 5I	Status
KBS001222	IEC BLOCK ADAPTER	23/04/2026	1	230	Pass	0.06	>99.90			Pass				Pass
KBS001223	AIR BLOWER	23/04/2026	1	230	Pass	0.10	>99.90		<0.10					Pass
KBS001224	AIR BLOWER	23/04/2026	1	230	Pass	0.08	>99.90		<0.10					Pass
KBS001225	AIR BLOWER	23/04/2026	1	230	Pass	0.06	>99.90		<0.10					Pass
KBS001226	AIR BLOWER	23/04/2026	1	230	Pass	0.07	>99.90		<0.10					Pass
KBS001229	32A TO 16A LEAD	23/04/2026	1	230	Pass	SKIPPE-SKIPPE-				Skip				Pass
KBS001233	3M EXTENSION LEAD	23/04/2026	1	230	Pass	0.10	>99.90			Pass				Pass
KBS001234	ICB BLOCK ADAPTOR	23/04/2026	1	230	Pass	0.06	>99.90			Pass				Pass
KBS001235	3M EXTENSION LEAD	23/04/2026	1	230	Pass	0.11	>99.90			Pass				Pass
KBS001239	AIR BLOWER	23/04/2026	1	230	Pass	0.07	>99.90		0.11					Pass
KBS001240	AIR BLOWER	23/04/2026	1	230	Pass	0.06	>99.90		<0.10					Pass
KBS001241	AIR BLOWER	23/04/2026	1	230	Pass	0.06	>99.90		<0.10					Pass
KBS001247	2 METER EXTENSION LEAD	23/04/2026	1	230	Pass	0.06	>99.90			Pass				Pass
KBS001251	3 METER DISCO LEAD	23/04/2026	1	230	Pass	0.10	>99.90			Pass				Pass
KBS001281	2 METER EXTENSION	23/04/2026	1	230	Pass	0.05	>99.90			Pass				Pass
KBS001282	2 METER EXTENSION	23/04/2026	1	230	Pass	0.05	>99.90			Pass				Pass
KBS001283	2 METER EXTENSION	23/04/2026	1	230	Pass	0.05	>99.90			Pass				Pass
KBS001284	2 METER EXTENSION	23/04/2026	1	230	Pass	0.06	>99.90			Pass				Pass
KBS001286	2 METER EXTENSION	23/04/2026	1	230	Pass	0.05	>99.90			Pass				Pass
KBS001291	htn213 extension lead	23/04/2026	1	230	Pass	0.05	>99.90			Pass				Pass
KBS001293	2M Extension Lead	23/04/2026	1	230	Pass	0.06	>99.90			Pass				Pass
KBS001294	2M Extension Lead	23/04/2026	1	230	Pass	0.05	>99.90			Pass				Pass
KBS001296	FAN	23/04/2026	1	230	Pass	0.08	>99.90		<0.10					Pass
KBS001297	FAN	23/04/2026	1	230	Pass	0.07	>99.90		<0.10					Pass
kbs001298	fan	23/04/2026	1	230	Pass	0.08	>99.90		0.10					Pass
KBS001299	FAN	23/04/2026	1	230	Pass	0.07	>99.90		0.11					Pass
KBS001300	FAN	23/04/2026	1	230	Pass	0.10	>99.90		<0.10					Pass
KBS001301	FAN 2HP	23/04/2026	1	230	Pass	0.07	>99.90		<0.10					Pass
KBS001303	25 M EXT LEAD	23/04/2026	1	230	Pass	0.24	>99.90			Pass				Pass
KBS001304	25M EXT	23/04/2026	1	230	Pass	0.26	>99.90			Pass				Pass
KBS001305	25M EXT	23/04/2026	1	230	Pass	0.25	>99.90			Pass				Pass
KBS001306	25M EXT	23/04/2026	1	230	Pass	SKIPPE-SKIPPE-				Skip				Pass
KBS001307	25M EXT	23/04/2026	1	230	Pass	0.26	>99.90			Pass				Pass
KBS001308	25M EXT	23/04/2026	1	230	Pass	0.25	>99.90			Pass				Pass
KBS001309	25M EXT	23/04/2026	1	230	Pass	0.26	>99.90			Pass				Pass
KBS001310	25M EXT	23/04/2026	1	230	Pass	0.25	>99.90			Pass				Pass
KBS001311	25M EXT	23/04/2026	1	230	Pass	0.26	>99.90			Pass				Pass
KBS001312	25M EXT	23/04/2026	1	230	Pass	0.26	>99.90			Pass				Pass

CONTRACTOR DETAILS

Blackhawk Security Ltd
Unit 5 Crowborough Business Park
Park Road
Crowborough
East Sussex TN6 2GZ

Tester Name Chris Hawkes
Qualifications City & Guilds 600/3528/6 - 600/3597/3
Position Director

Signature



APPLIANCE TESTING CERTIFICATE

Certificate No.: 37

Instrument Serial No.:

1000-755/101035672

CLIENT AND LOCATION DETAILS

KBS Inflatable Kingdom
Unit 2 Crowborough Business Park
Park Road
Crowborough
TN6 2GZ

Blackhawk Security Ltd
Unit 6A Crowborough Business Park
Park Road
Crowborough
TN6 2GZ

TEST RESULTS

Asset ID	Description	Test Date	Class	Volts	Visual	Cont	Ins.	Oper.	Leak.	Extn.	Flash	RCD I	RCD 5I	Status
KBS001313	25M EXT	23/04/2026	1	230	Pass	0.25	>99.90			Pass				Pass
KBS001314	25M EXT	23/04/2026	1	230	Pass	0.26	>99.90			Pass				Pass
KBS001315	25M EXT	23/04/2026	1	230	Pass	0.25	>99.90			Pass				Pass
KBS001316	25M EXT	23/04/2026	1	230	Pass	0.25	>99.90			Pass				Pass
KBS001317	25M EXT	23/04/2026	1	230	Pass	0.26	>99.90			Pass				Pass
KBS001318	25M EXT	23/04/2026	1	230	Pass	0.25	>99.90			Pass				Pass
KBS001319	25M EXT	23/04/2026	1	230	Pass	0.26	>99.90			Pass				Pass
KBS001320	25M EXT	23/04/2026	1	230	Pass	0.25	>99.90			Pass				Pass
KBS001321	25M EXT	23/04/2026	1	230	Pass	0.25	>99.90			Pass				Pass
KBS001322	25M EXT	23/04/2026	1	230	Pass	0.25	>99.90			Pass				Pass
KBS001323	25M EXT	23/04/2026	1	230	Pass	0.25	>99.90			Pass				Pass
KBS001324	25M EXT	23/04/2026	1	230	Pass	0.26	>99.90			Pass				Pass
KBS001324	25M EXT	23/04/2026	1	230	Pass	0.26	>99.90			Pass				Pass
KBS001325	25M EXT	23/04/2026	1	230	Pass	0.25	>99.90			Pass				Pass
KBS001326	25M EXT	23/04/2026	1	230	Pass	0.26	>99.90			Pass				Pass
KBS001327	10M EXT	23/04/2026	1	230	Pass	0.13	>99.90			Pass				Pass
KBS001328	10M EXT	23/04/2026	1	230	Pass	0.14	>99.90			Pass				Pass
KBS001329	10M EXT	23/04/2026	1	230	Pass	0.13	>99.90			Pass				Pass
KBS001330	10M EXT	23/04/2026	1	230	Pass	0.13	>99.90			Pass				Pass
KBS001331	10M EXT	23/04/2026	1	230	Pass	0.13	>99.90			Pass				Pass
KBS001332	10M EXT	23/04/2026	1	230	Pass	0.13	>99.90			Pass				Pass
KBS001335	10M EXT	23/04/2026	1	230	Pass	0.06	>99.90		<0.10					Pass
KBS001336	10M EXT	23/04/2026	1	230	Pass	0.06	>99.90		<0.10					Pass
KBS001337	10M EXT	23/04/2026	1	230	Pass	0.06	>99.90		0.10					Pass
kbs001338	25M EXT	23/04/2026	1	230	Pass	0.26	>99.90			Pass				Pass
kbs001339	25M EXT	23/04/2026	1	230	Pass	0.26	>99.90			Pass				Pass
kbs001340	25M EXT	23/04/2026	1	230	Pass	0.26	>99.90			Pass				Pass
kbs001341	25M EXT	23/04/2026	1	230	Pass	0.25	>99.90			Pass				Pass
kbs001342	25M EXT	23/04/2026	1	230	Pass	0.26	>99.90			Pass				Pass
kbs001343	25M EXT	23/04/2026	1	230	Pass	0.25	>99.90			Pass				Pass
KBS001344	25M EXT	23/04/2026	1	230	Pass	0.25	>99.90			Pass				Pass
KBS001345	25M EXT	23/04/2026	1	230	Pass	0.25	>99.90			Pass				Pass
KBS001346	25M EXT	23/04/2026	1	230	Pass	0.25	>99.90			Pass				Pass
KBS001347	25M EXT	23/04/2026	1	230	Pass	0.25	>99.90			Pass				Pass
KBS001348	25M EXT	23/04/2026	1	230	Pass	0.25	>99.90			Pass				Pass
KBS001349	25M EXT	23/04/2026	1	230	Pass	0.25	>99.90			Pass				Pass
KBS001350	10M EXT	23/04/2026	1	230	Pass	0.13	>99.90			Pass				Pass
KBS001351	10M EXT	23/04/2026	1	230	Pass	0.14	>99.90			Pass				Pass

CONTRACTOR DETAILS

Blackhawk Security Ltd
Unit 5 Crowborough Business Park
Park Road
Crowborough
East Sussex TN6 2GZ

Tester Name Chris Hawkes
Qualifications City & Guilds 600/3528/6 - 600/3597/3
Position Director

Signature



APPLIANCE TESTING CERTIFICATE

Certificate No.: 37

Instrument Serial No.:

1000-755/101035672

CLIENT AND LOCATION DETAILS

KBS Inflatable Kingdom
Unit 2 Crowborough Business Park
Park Road
Crowborough
TN6 2GZ

Blackhawk Security Ltd
Unit 6A Crowborough Business Park
Park Road
Crowborough
TN6 2GZ

TEST RESULTS

Asset ID	Description	Test Date	Class	Volts	Visual	Cont	Ins.	Oper.	Leak.	Extn.	Flash	RCD I	RCD 5I	Status
KBS001352	10M EXT	23/04/2026	1	230	Pass	0.13	>99.90			Pass				Pass
KBS001353	10M EXT	23/04/2026	1	230	Pass	0.14	>99.90			Pass				Pass
KBS001354	10M EXT	23/04/2026	1	230	Pass	0.13	>99.90			Pass				Pass
KBS001355	10M EXT	23/04/2026	1	230	Pass	0.13	>99.90			Pass				Pass
KBS001356	10M EXT	23/04/2026	1	230	Pass	0.13	>99.90			Pass				Pass
KBS001357	10M EXT	23/04/2026	1	230	Pass	0.13	>99.90			Pass				Pass
KBS001358	10M EXT	23/04/2026	1	230	Pass	0.13	>99.90			Pass				Pass
KBS001359	10M EXT	23/04/2026	1	230	Pass	0.13	>99.90			Pass				Pass
KBS001361	10M EXT	23/04/2026	1	230	Pass	0.13	>99.90			Pass				Pass
KBS001362	10M EXT	23/04/2026	1	230	Pass	0.13	>99.90			Pass				Pass
KBS001363	10M EXT	23/04/2026	1	230	Pass	0.13	>99.90			Pass				Pass
KBS001364	10M EXT	23/04/2026	1	230	Pass	0.13	>99.90			Pass				Pass
KBS001367	2M EXT	23/04/2026	1	230	Pass	0.05	>99.90			Pass				Pass
KBS001368	2M EXT	23/04/2026	1	230	Pass	0.04	>99.90			Pass				Pass
KBS001369	2M EXT	23/04/2026	1	230	Pass	0.05	>99.90			Pass				Pass
KBS001370	2M EXT	23/04/2026	1	230	Pass	0.05	>99.90			Pass				Pass
KBS001371	2M EXT	23/04/2026	1	230	Pass	0.05	>99.90			Pass				Pass
KBS001372	2M EXT	23/04/2026	1	230	Pass	0.05	>99.90			Pass				Pass
KBS001373	2M EXT	23/04/2026	1	230	Pass	0.04	>99.90			Pass				Pass
KBS001374	2M EXT	23/04/2026	1	230	Pass	0.04	>99.90			Pass				Pass
KBS001375	2M EXT	23/04/2026	1	230	Pass	0.05	>99.90			Pass				Pass
KBS001376	2M EXT	23/04/2026	1	230	Pass	0.05	>99.90			Pass				Pass
KBS001377	2M EXT	23/04/2026	1	230	Pass	0.05	>99.90			Pass				Pass
KBS001378	2M EXT	23/04/2026	1	230	Pass	0.05	>99.90			Pass				Pass
KBS001379	2M EXT	23/04/2026	1	230	Pass	0.05	>99.90			Pass				Pass
KBS001380	2M EXT	23/04/2026	1	230	Pass	0.04	>99.90			Pass				Pass
KBS001381	2M EXT	23/04/2026	1	230	Pass	0.05	>99.90			Pass				Pass
KBS001382	2M EXT	23/04/2026	1	230	Pass	0.05	>99.90			Pass				Pass
KBS001384	2M EXT	23/04/2026	1	230	Pass	0.05	>99.90			Pass				Pass
KBS001385	2M EXT	23/04/2026	1	230	Pass	0.05	>99.90			Pass				Pass
KBS001386	2M EXT	23/04/2026	1	230	Pass	0.05	>99.90			Pass				Pass
KBS001387	2M EXT	23/04/2026	1	230	Pass	0.05	>99.90			Pass				Pass
KBS001388	2M EXT	23/04/2026	1	230	Pass	0.05	>99.90			Pass				Pass
KBS001389	2M EXT	23/04/2026	1	230	Pass	0.04	>99.90			Pass				Pass
KBS001390	2M EXT	23/04/2026	1	230	Pass	0.04	>99.90			Pass				Pass
KBS001391	2M EXT	23/04/2026	1	230	Pass	0.05	>99.90			Pass				Pass
KBS001392	2M EXT	23/04/2026	1	230	Pass	0.08	>99.90			Pass				Pass
KBS001393	2M EXT	23/04/2026	1	230	Pass	0.07	>99.90			Pass				Pass

CONTRACTOR DETAILS

Blackhawk Security Ltd
Unit 5 Crowborough Business Park
Park Road
Crowborough
East Sussex TN6 2GZ

Tester Name
Qualifications
Position

Chris Hawkes
City & Guilds 600/3528/6 - 600/3597/3
Director

Signature



APPLIANCE TESTING CERTIFICATE

Certificate No.: 37

Instrument Serial No.:

1000-755/101035672

CLIENT AND LOCATION DETAILS

KBS Inflatable Kingdom
Unit 2 Crowborough Business Park
Park Road
Crowborough
TN6 2GZ

Blackhawk Security Ltd
Unit 6A Crowborough Business Park
Park Road
Crowborough
TN6 2GZ

TEST RESULTS

Asset ID	Description	Test Date	Class	Volts	Visual	Cont	Ins.	Oper.	Leak.	Extn.	Flash	RCD I	RCD 5I	Status
KBS001394	2M EXT	23/04/2026	1	230	Pass	0.07	>99.90			Pass				Pass
KBS001395	2M EXT	23/04/2026	1	230	Pass	0.07	>99.90			Pass				Pass
KBS00360	10M EXT	23/04/2026	1	230	Pass	0.13	>99.90			Pass				Pass

CONTRACTOR DETAILS

Blackhawk Security Ltd
Unit 5 Crowborough Business Park
Park Road
Crowborough
East Sussex TN6 2GZ

Tester Name
Qualifications
Position

Chris Hawkes
City & Guilds 600/3528/6 - 600/3597/3
Director

Signature

